Joslyn Clark Controls
2013 W. Meeting St
Lancaster, SC

Fire Pump Control Spec Sheet

Project:		Location:	
Distributor:			
Contractor:			
Catalog Number:			

Dimensional Drawing	
Field Connection Drawing	
Electrical Schematic	

Horsepower

Type of Control
☐ Full Service Control
☐ Limited Service Cntrl

Starting Method
☐ Across-the-Line
☐ Solid State Soft Start
☐ Autotransforer
☐ Primary Resistor
☐ Part Winding
☐ Wye-Delta Closed
☐ Wye-Delta Open

Interupting Rating
☐ 14K AIC
☐ 18K AIC
☐ 30K AIC
☐ 42K AIC
☐ 100K AIC
☐ 150K AIC
☐ 200K AIC

3 Phase
☐ 208 / 3 / 60
☐ 230 / 3 / 60
☐ 460 / 3 / 60
☐ 575 / 3 / 60

Enclosure
☐ 2 - Drip Proof - (std)
☐ 3R - Rain Tight
☐ 12 - Dust Tight
☐ 4 - Water Tight -Paint
☐ 4X - Water Tight - SS

Special Options

- ☐
- ☐
- ☐
- ☐
- ☐
- ☐
- ☐